

Taking LUX Readings

- ▶ Calibrated meter (need to know brand, model and serial number)
- ▶ Must meet AS1680/BCA requirements **PLUS 20%** on average over measured area.
 - ▶ LED upgrade lights are expected to last 10 years and are determined by regulator to depreciate by 20% over that time period, thus still meeting required AS1680/BCA requirements at end of life.
 - ▶ Chart on next screen shows AS1680 minimum lux levels for specific class of tasks
- ▶ LUX readings where possible should be taken at night and must not include natural daylight