

LUX level requirements

- Take lux levels at night, or with daylight excluded from the space
 - This can be achieved by taking two readings one with lights on and one with lights off. The difference would represent the light output of upgrade lighting.
- Measurement points must be no more than 1m apart, and no closer than 1m to a wall
- For spaces greater than 25m², the test area must be at least 9m² and cover 4 luminaires. Make the test area larger if the luminaires are further apart.
- For spaces smaller than 25m², the entire floor space should be measured, 1m away from walls with a minimum of 9 measurements. This means in small spaces, the measurements may be less than 1m apart.