

Update ceiling plan with lux test areas



Upgrade Lighting Plan must show where lux readings were taken as auditor will go to same location to take their own readings