

Record the measurements in a table

Area / room	Class of task	Size of test area (m ²)	Number of measurements	Height of measurements from floor	Average Lux	Required Lux
Carpark 1	Rough, intermittent use	15m ²	15	0.0 m	112 lux	100 Lux PASS
Office 1	Moderately difficult	4.5m ²	9	0.9 m	439 lux	400 Lux PASS
Main office	Moderately difficult	12m ²	12	0.9 m	758	400 Lux PASS